

# Combustion and Fuels

Luke Cowell
Solar Turbines Incorporated



#### **Overview**

- Gas Turbine Combustion Systems & Emissions
- Dry Low Emissions (DLE) Combustion
- Gas Turbine Fuels
- Future Combustion Technologies




#### **Overview**

- Gas Turbine Combustion Systems & Emissions
- Dry Low Emissions (DLE) Combustion
- Gas Turbine Fuels
- Future Combustion Technologies



# **Typical Gas Turbine Combustion System**





# **Combustion System Design Criteria**

- Reliable Ignition
- Good Combustion Stability
- High Combustion Efficiency
- Low Smoke
- Satisfactory Emissions Levels
- Minimum Pressure Loss
- Satisfactory Combustor Exit
- Temperature Distribution
- Life

**Operation** 

**Environmental Regulations** 

**Performance** 

**Durability** 



## **Industrial Gas Turbine Combustion Systems**

- Conventional Combustion
  - Diffusion Combustion
  - Historical Design
- Dry Low Emissions (DLE or DLN) "SoLoNOx"
  - Lean Premixed Combustion
  - Superior Emissions Performance
  - Offered Since 1992



#### **Diffusion Flames**

Fuel and Air Mix and Burn At the Same Time



#### **Premixed Flames**

Fuel and Air Mix and Then Burn






# Effect of Stoichiometry on Flame Temperature and NOx Emissions

CONVENTIONAL Flame Temperature (Diffusion Flame) NOx Emissions **LEAN PREMIXED** LEAN **EXTINCTION** Rich Lean

**Fuel/Air Ratio** 




#### **Emissions Characteristics**





# **Combustion System NOx Emission Capabilities**





#### **Overview**

- Gas Turbine Combustion Systems & Emissions
- Dry Low Emissions (DLE) Combustion
- Gas Turbine Fuels
- Future Combustion Technologies




#### **DLE is Pollution Prevention**

Reduction of Combustion-Generated
Exhaust Emissions through
Understanding and Control of
Combustion Process

**More Cost-Effective Than Exhaust Clean Up** 




- Lean Premixed Combustion Reduces NOx, CO and UHC Emissions
- NOx are Reduced
  - Lowering Flame Temperature
    - Lean Combustion
    - Premixing to Eliminate "Hot Spots"
- CO and UHC are Reduced
  - Increasing Combustion Residence Time (Volume)
  - Combustor Design to Prevent Local Quenching





# SoLoNOx Engine and Package Changes from Conventional Combustion Systems

- Combustor Liner
- Fuel Injectors
- Engine Casings
- Fuel System
- Control System











- Lean Premixed Combustion
- Diesel No. 2 and Kerosene
- Main and Pilot Fuel Circuits on Both Fuels
- Same Combustor Liner as Gas Only

- First Unit Commissioned
   1992 for 42 ppm on Gas
- First Dual Fuel DLE Unit Commissioned in 1994
- Units Capable of 25 ppm Ship in 1995
- Units Offered at 15 ppm or Less (with restrictions) in 2000
- Estimate >1400 DLE Units\* Worldwide
- Nearly 1000 SoLoNOx Units Sold\*\*



\*<30,000 Hp

\*\*Solar Turbines Only




## Operation and Conditions That Increase Emissions on DLE Units

- Low Load and Load Transients
- Fuel Type and Quality
- Combustor Induced Pressure Oscillations
- Extremely Cold Ambients




### **General Trends for NOx, and CO**





# **Combustion-Induced Oscillations**

- Potential in All Lean-Premixed Combustion Systems
- Oscillations Present When Fuel Heat Release in Phase with Combustor Acoustic Frequency
- Rumble is Lower Frequency Flame Instability





# **Current SoLoNOx Operation Below 0°F (-18°C)**


- Engine Operation Not Impacted
- Pilot Increases to Control Rumble and Prevent Flameout on Some Engine Models
- NOx and CO Emissions Increase
- Development in Progress To Reduce Emissions



#### **Overview**


- Gas Turbine Combustion Systems & Emissions
- Dry Low Emissions (DLE) Combustion
- Gas Turbine Fuels
- Future Combustion Technologies

### **Gas Turbine Fuels**






# Impact of Gas Fuel Energy Content on Conventional Gas Turbine and Control Systems






#### **Effect of Gas Fuel Type on NOx Emissions**





#### **DLE Gas Turbine Range**





# Potential Effect of Fuel Type on DLE Turbines

#### Durability

- Autoignition
- Flashback
- Oscillations
- Contamination
- Emissions

#### **Fuel Quality**

- Gas Fuel Natural Gas
  - Fuel Variability: Wobbe of 1220 ±10%
  - Gas Supply Temperature >+50°F (10°C) Dew Pt
  - No Liquids Allowed in Fuel Gas
  - Particulate Limits

#### Liquid Fuel

- Viscosity
- Distillation
- Particulate
- Contaminants (Rust, Water, Salt, Others)



#### **Overview**

- Gas Turbine Combustion Systems & Emissions
- Dry Low Emissions (DLE) Combustion
- Gas Turbine Fuels
- Future Combustion Technologies



# Developments For Lower Emissions with Lean Premixed Combustion Systems


- Combustor Liner
- Advanced Injectors
- Controls Technology
- Reducing Manufacturing Variations



# **Ultra Low Emissions**

- Technologies to Allow Combustion at Lower Flame Temperatures
- Potential for Low Single Digit NOx Levels







- Conventional Combustion Systems Offer Maximum Turbine Operation and Fuel Flexibility
- DLE Gas Turbines Have Been Successfully Introduced
- DLE Offers Ten Fold Decrease in Turbine Emissions
- Cost Effective Compared to Exhaust Clean-Up
- DLE Presents Turbine Operators with Some Limitations
- Potential to Reduce Emissions Further



